



UL LISTED, cUL CERTIFIED.
 CLASS I DIVISION 2, GROUPS A, B, C, D.
 CLASS II DIVISION 2, GROUP F, G.
 CLASS III. ENCLOSURE TYPE 4X
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMP117.

186	486	8 TO 200	0.6 TO 13.8
185	485	4 TO 100	0.3 TO 6.9
184	484	2 TO 50	0.1 TO 3.4
183	483	1 TO 20	68.9 TO 1379 mbar
MODEL NO.		psi	bar
ADJUSTABLE RANGE			
LOW END OF RANGE ON FALL			
HIGH END OF RANGE ON RISE			

COVER REMOVED IN FRONT VIEW

SYM	DESCRIPTION	DATE	DVN	APPD
P	CHANGED kPa TO bar. ECN#E0047	10-23-02	S.R.	H.N.
N	REVISED VIEW OF TERMINAL BLOCK & SPECS. ECN#C8438	11-22-99	S.R.	VPD
M	CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775	12-3-98	P.V.	S.F.
L	REDRAWN. ADDED 1" (25.4mm) & 3/16 (7.94mm) DIMENSIONS. ECN#C684B	10-31-97	P.W.	A.M.

ORIGINAL DATE	2-4-91
DRWN	PETER WEILER
CHKD	PETER WEILER
APPD	G. YUSKAUSKAS
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	
DO NOT SCALE THIS DRAWING	

TITLE	H117
SCALE	HALF

DF001D

UNITED ELECTRIC CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS

DWG NO
 A-12845