

計装ネットワークモジュールNX スーパーバイザーモジュールNX-S01 取扱説明書 設置編



このたびは当社製品をご購入いただき、まことにありがとうございます。この取扱説明書には、製品を安全に正しくご使用いただくための必要事項が記載されております。当社製品を使用した操作盤、装置の設計、保守を担当される方は、必ずお読みになり、理解したうえでご使用ください。いつもお手元においてご活用ください。

ご注文・ご使用に際しては、下記URLより「ご注文・ご使用に際してのご承諾事項」を必ずお読みください。

<http://www.azbil.com/jp/product/factory/order.html>

お願い

この取扱説明書は、本製品をお使いになる担当者のお手元に確実に届くようにお取りはからいください。

この取扱説明書の全部、または一部を無断で複写、または転載することを禁じます。この取扱説明書の内容を将来予告なしに変更することがあります。

この取扱説明書の内容については、万全を期しておりますが、万一ご不審な点や記入もれなどがありましたら、当社までご連絡ください。

お客様が運用された結果につきましては、責任を負いかねる場合がございますので、ご了承ください。

© 2012-2017 Azbil Corporation All Rights Reserved.

Modbus™ is a trademark and the property of Schneider Electric SE, its subsidiaries and affiliated companies.

安全上の注意

この安全上の注意は、製品を安全に正しくお使いいただき、あなたや他の人々への危害や財産への損害を未然に防止するためのものです。安全上の注意は必ず守ってください。また、内容をよく理解してから本文をお読みください。当社が規定しない使い方をした場合、この製品に盛り込まれた安全保護は損なわれます。

● 警告表示の意味



警告

取り扱いを誤った場合に、使用者が死亡または重傷を負う危険の状態が生じることが想定される場合。



注意

取り扱いを誤った場合に、使用者が軽傷を負うか、または物的損害のみが発生する危険の状態が生じることが想定される場合。

警告



本器の取り付け、取り外し、および結線のときは、本器および接続機器の電源をすべて切ってください。感電することがあります。



本器への通電前に配線が正しく行われていることを確認してください。本器への配線間違いは危険な災害を招く原因になり、また故障の原因にもなります。

注意



DINレールストップはドライバなど工具を使用して取り付け、取り外しをしてください。



本器を分解しないでください。故障のおそれがあります。



本器の通風穴をふさがないでください。火災、故障のおそれがあります。



本器のケース内部に線くず、切粉、水などが入らないようにしてください。火災、故障のおそれがあります。



電源端子などの充電部には触らないでください。感電のおそれがあります。



本器への結線は電源を切った状態で行ってください。故障のおそれがあります。



本器への結線は定められた基準に従い、指定された電源、および施工方法で正しく配線してください。火災、感電、故障のおそれがあります。



接続箇所に緩みがないことを確認してください。発熱および装置の故障の原因となるおそれがあります。



連結されたモジュール全体の消費電力の総和が70 Wを超えないようにしてください。火災、故障のおそれがあります。



連結されたモジュール全体に2系統以上の電源を供給しないでください。火災、故障のおそれがあります。



本器の未使用端子を中継端子として使用しないでください。火災、感電、故障のおそれがあります。



出力部を短絡しないでください。故障のおそれがあります。



端子ねじは仕様に記載されたトルクで確実に締めてください。締め付けが不完全だと火災のおそれがあります。



雷サージのおそれがある場合には、サージアブソーバ(サージ防止器)を使用してください。火災、故障のおそれがあります。



本器は仕様に記載された使用条件(温度、湿度、電圧、振動、衝撃、取付方向、雰囲気など)の範囲内でお使いください。火災、故障のおそれがあります。



本器は電源投入後、約60秒間動作しません。本器からの出力をインターロック信号として使用する場合には注意してください。



指定(形番: 83170639-001)のバッテリーを使用してください。火災または破裂のおそれがあります。



本器を廃棄するときは、内蔵のバッテリーを取り外し、産業廃棄物として各自治体の条例に従って適切に処理してください。



使用後のバッテリーは、各自治体の条例または規則に従って適切に処理してください。



購入時にあらかじめ設定されているカスタムアプリケーションの設定内容を変更する場合には、お客様自身の責任で十分な検証を行ってください。



本器は電気の知識を有する専門の方が扱ってください。



製造者が指定しない方法で本器を使用すると、本器が備える保護機能が損傷する可能性があります。



本器の汚れを取る場合は柔らかい布で乾拭きしてください。シンナー、ベンゼンなどの有機溶剤や洗剤は使用しないでください。



本器に接続する機器または装置は、本器の電源、入出力部の最高使用電圧に適した強化絶縁が施されているものをご使用ください。

概要

計装ネットワークモジュールNXは、イーサネットの標準採用により「分散計装」、「高速通信」、「省配線」、「省エンジニアリング」を実現し、お客様に環境・品質・生産性向上という価値をご提供いたします。

スーパーバイザーモジュールNX-S01はファンクションブロックプログラミング機能を搭載し、計装ネットワークモジュールNXの調節計モジュール、デジタル入力/パルス入力モジュールおよびデジタル出力モジュールの入出力演算機能と通信を行い、計測/制御機能を提供します。

形番構成


■ スーパーバイザーモジュール

基本形番	タイプ	リング接続	オプション			追加処理	
			1	2	3		
NX-	S01					計装ネットワークモジュール	
							カスタムアプリケーションモデル
		N					ノンリング通信
		R					リング通信
			0				なし
				00			なし
					0		なし
						1	故障状態出力接点(1点)付き
						0	なし
						D	検査成績書付
						T	熱帯処理品
						K	硫化対策処理品
				B	熱帯処理品+検査成績書付		
				L	硫化対策処理品+検査成績書付		


各部の名称

■ 本体

本体の表示部は形番(機能)によって異なります。




■ ベース



取り付け

■ 取付場所

屋内に取り付けてください。
図の数値は最低限必要な間隔です。



* バッテリーを通電状態で交換する場合のスペースは60mm以上としてください。

次のようなところには取り付けないでください。

- 仕様の範囲を超えた高温、低温、高湿度、低湿度になるところ
- 硫化ガスなど腐食性ガスのあるところ
- 粉じん、油煙などのあるところ
- 直射日光、風雨が当たるところ
- 仕様の範囲を超えた機械的振動、衝撃のあるところ
- 高圧線の下、溶接機および電気的ノイズの発生源の近く
- ボイラなどの高圧点火装置から15 m以内
- 電磁界の影響のあるところ
- 可燃性の液体や蒸気のあるところ
- 屋外
- 入出力のコモンモード電圧：対大地間の電圧が30 Vrms以上、42.4 Vピーク以上、DC60 V以上のところ

■ モジュールの連結

本器はベース左右のコネクタで別のモジュールと連結できます。
連結することで、各モジュールの電源および通信が接続され、配線を省くことができます。RS-485通信は、ベースのRS-485通信切り離しスイッチで右側モジュールとの連結接続を切り離すことができます。

■ 取付方法


本器はDINレールに取り付けて使用します。
DINレールを固定したあと、DINレールストップパを十分引き出してからベースをレールに引っ掛けてください。
次にDINレールストップパを上方にカチッと音がするまで押し込んでください。

⚠ 取り扱い上の注意

- 本器は垂直な面にDINレールストップパを下側にして取り付けてください。
- 本器はDINレールに取り付ける前に連結を行ってください。

■ 本体をベースに取り付ける

- ① 本体下部のフックをベースに引っ掛けてください。
- ② 本体上部のレバーがカチッと音がするまではめ込んでください。




❗ 取り扱い上の注意


- 同梱されているベースと本体の組み合わせは対にして使用してください。
- 最初に本体下部のフックをベースに引っ掛けてください。フックが破損することがあります。

■ 本体をベースから取り外す


- ① 本体を奥に向かって押さえつけてください。



- ② 本体を押さえつけたまま本体上部のレバー先端を押してください。




- ③ レバー先端を押したまま、本体を上部から手前に引き、回転するように取り外してください。



❗ 取り扱い上の注意

- レバー先端を2 mm以上押し込まないでください。レバーが折れる可能性があります。




■ 結線上の注意


- 配線については、内線規定、電気設備技術基準に従って施工してください。
- 屋外配線はしないでください。落雷時破損することがあります。
- 電源線の末端は絶縁被覆付きの圧着端子を使用してください。
- 結線は計器形番と端子番号を本体側面の配線図で確認してから行ってください。
- 電源端子、RS-485通信端子の接続にはM3のねじに適合する圧着端子を使ってください。
- 圧着端子などが隣の端子と接触しないように注意してください。
- 本器の信号線や電源線は、他の動力線や他の電源線から60 cm以上離してください。また、同一の配線管やダクト内を通さないでください。
- 他の計器と並列接続する場合は、他の計器の条件をよく調べてから計装してください。
- 本器は電源投入後、安定のため約60秒間は機能しないようになっています。
- 結線が終わったら、通電前に配線間違いのないことを確認してください。

■ 故障DOコネクタの接続(故障DO付きモデル)


故障DOは、付属の2ピース端子台の仕様に合わせて接続してください。



● 接続図



● 故障DO回路



● 基準条件

周囲温度	: 23 ± 2°C
周囲湿度	: 60 ± 5%RH (結露なきこと)
定格電源電圧	: DC24 V
振動	: 0 m/s ²
衝撃	: 0 m/s ²
取付角度	: 基準面±3°

● 動作条件

周囲温度	: 0 ~ 50°C (設置した状態での本器下面側にて)
周囲湿度	: 10 ~ 90%RH (結露なきこと)
入力可能電圧	: DC21.6 ~ 26.4 V
振動	: 0 ~ 3.2 m/s ² (10 ~ 150 Hz XYZ各方向2h)
衝撃	: 0 ~ 9.8 m/s ²
取付角度	: 基準面±3°
じん埃	: 0.3 mg/m ³ 以下
腐食性ガス	: なきこと
高度	: 2000 m以下
汚染度 (Pollution degree)	: 2 (通常のオフィス環境と同等)

● 輸送保管条件

周囲温度	: -20 ~ +70°C
周囲湿度	: 5 ~ 95%RH (結露なきこと)
振動	: 0 ~ 9.8 m/s ² (10 ~ 150 Hz XYZ各方向2h)
衝撃	: 0 ~ 300 m/s ² (DIN レール取付状態、上下方向3回)
包装落下試験	: 落下高さ 60 cm (1角3稜6面の自由落下法による)

● その他

メモリバックアップ	: 不揮発性メモリ (フラッシュ ROM)、 およびバッテリーによる SRAM のバックアップ
フラッシュ ROM 書き込み回数	: 10 万回以下
絶縁抵抗	: DC500 V、20 MΩ 以上 (電源端子①②と、 電源端子と絶縁された I/O 端子間)
耐電圧	: AC500 V、1 min (電源端子①②と、電 源端子と絶縁された I/O 端子間)
消費電力	: 4 W 以下 (動作条件にて)
電源投入時の動作	: リセット時間約 10 s (通常動作を行うま での時間、基準条件にて)
電源投入時突入電流	: 12 A 以下 (動作条件にて)
外形寸法	: 30 × 100 × 85 mm
ケース材質、色	: 変性 PPO 樹脂、黒
適合規格	: CE (EN61326-1、For use in industrial locations)、cUL (UL61010-1)
取付方法	: DIN レール取付
端子ねじ適正締付トルク	: 0.6 ± 0.1 N·m
質量	: 200 g 以下
時計 IC	: 内蔵 RTC、± 2.2 s/日 カレンダー付き (基準条件にて)
バッテリー寿命	: 3 年間 (無通電時、基準条件にて)
付属品	: 故障状態出力接点付きに専用コネクタ (1 個) が付属
保守部品 (別売品)	: 交換用バッテリー 形番: 83170639-001

● 通信仕様

● 上位通信

最大接続数	: 2、3 (NX-S01 単独で使用する場合)
注	RS-485 通信とイーサネット通信のセッ ション数の合計、RS-485 通信を使用する場 合はイーサネット通信は (最大接続数 - 1) セッションに制限されます

● イーサネット通信

プロトコル	: CPL/TCP、Modbus/TCP
注	上位通信接続を行う場合には、必ずコミュ ニケーションボックスを使用してください。 ただし、モジュール本体に印字されている S/N の上位 4 桁が 1144 以下の NX-CB1RR は使用できません

● RS-485 通信

プロトコル	: CPL、Modbus/RTU、Modbus/ASCII
ネットワーク	: マルチドロップ方式 (親局 1 台に対する子局として 31 台)
信号レベル	: RS-485 に準ずる
通信/同期方式	: 半 2 重 / 調歩同期式
最大線路長	: 500 m
通信線数	: 3 線式
終端抵抗	: 外付け (150 Ω 1/2 W 以上)
伝送速度	: 4800、9600、19200、38400、57600、 115200 bps から選択可能
ビット長	: 7 ビットまたは 8 ビット
ストップビット	: 1 ビットまたは 2 ビット
パリティビット	: 偶数パリティ、奇数パリティ、または パリティなし

● ローダ通信

専用ローダ	: SLP-NX-J70、SLP-NX-J70PRO SLP-NX-J71、SLP-NX-J71PRO
-------	--

● コミュニケーションボックス

(別売 形番: NX-CB□□□□□□□)	
ポート数	: 4
伝送路形式	: ● イーサネットポート 1、2 IEEE802.3/IEEE802.3u 10BASE-T/100BASE-TX (オートネゴシエーション、 Auto MDI/MDI-X 機能あり)
	● イーサネットポート 3、4 (オプション 0) イーサネットポート 3 (オプション 1) IEEE802.3u 100BASE-TX (Full Duplex、Auto MDI/MDI-X 機能 あり。コミュニケーションボックス間 を接続する場合は、接続する機器 はオートネゴシエーション機能が有効 であること)
	● イーサネットポート 4 (オプション 1) IEEE802.3u 100BASE-FX (Full Duplex、波長 1300 nm)
コネクタ	: ● 100BASE-TX コネクタ RJ-45 ● 100BASE-FX コネクタ 2 心 LC
ケーブル	: ● 100BASE-TX ケーブル UTP ケーブル (4P) Cat5e 以上 (ストレート) (両端 ANSI/TIA/EIA- 568B) 最長 100 m
	● 100BASE-FX ケーブル マルチモード・グレーテッドインデッ クスタイプ (屈折率分布型) 光ファイバーケーブル GI-50/125 または GI-62.5/125 (2 心) 最長 2 km
注	光ファイバーケーブルの取り扱いについ ては光ファイバーメーカーの注意事項を ご覧ください

● コミュニケーションアダプタ

(別売 形番：NX-CL1□□□□□□、NX-CR1□□□□□□)
 ポート数 : 1
 伝送路形式 : IEEE802.3u 100BASE-TX
 (Full Duplex、Auto MDI/MDI-X機能あり。
 接続する機器はオートネゴシエーション
 機能が有効であること)
 コネクタ : RJ-45
 ケーブル : UTPケーブル(4P)
 Cat 5e以上(ストレート)
 (両端ANSI/TIA/EIA-568-B)

● ターミナルアダプタ

(別売 形番：NX-TL1□□□□□□、NX-TR1□□□□□□)
 チェーン接続リング通信端(ベース内イーサネット通信
 経路)として使用するためのアダプタです。

● 交換バッテリー(別売 形番：83170639-001)

形状 : コネクタケーブル付きボタン型バッテリー
 個数 : 1個


● コネクタキャップ

(別売 形番：80700224-010(オス用)、80700225-010(メス用))
 サイドコネクタ(オス、メス)を保護するためのキャ
 ップです。
 モジュール本体正面から見て、右側のコネクタがオス、
 左側のコネクタがメスになります。
 個数 : 10個

■ 外形寸法図


● 標準品

単位：mm



● 故障状態出力接点付き

単位：mm



[ご注意] この資料の記載内容は、お断りなく変更する場合がありますので
 ご了承ください。(26)

アズビル株式会社
アドバンスオートメーションカンパニー

本社 〒100-6419 東京都千代田区丸の内2-7-3 東京ビル
 北海道支店 ☎(011)211-1136 中部支店 ☎(052)324-9772
 東北支店 ☎(022)290-1400 関西支店 ☎(06)6881-3383~4
 北関東支店 ☎(048)621-5070 中国支店 ☎(082)554-0750
 東京支店 ☎(03)6432-5142 九州支店 ☎(093)285-3530

製品のお問い合わせは…
 コールセンター： ☎0466-20-2143

(アズビル株式会社) <http://www.azbil.com/jp/>
 (COMPO CLUB) <http://www.compoclub.com>

2012年 4月 初版発行(V)
 2017年 11月 改訂5版(F)

Network Instrumentation Modules NX-S01 Supervisor Module User's Manual for Installation



Thank you for purchasing an Azbil Corporation product. This manual contains information for ensuring the correct use of this product. This manual should be read by those who design and maintain equipment that uses this product. Be sure to keep this manual nearby for handy reference. Please read "Terms and Conditions" from the following URL before ordering and use.
<http://www.azbil.com/products/factory/order.html>

NOTICE

Be sure that the user receives this manual before the product is used. Copying or duplicating this user's manual in part or in whole is forbidden. The information and specifications in this manual are subject to change without notice. Considerable effort has been made to ensure that this manual is free from inaccuracies and omissions. If you should find an error or omission, please contact the azbil Group. In no event is Azbil Corporation liable to anyone for any indirect, special or consequential damages as a result of using this product.

© 2012–2017 Azbil Corporation All Rights Reserved.

Modbus™ is a trademark and the property of Schneider Electric SE, its subsidiaries and affiliated companies.

SAFETY PRECAUTIONS

Safety precautions are for ensuring safe and correct use of this product, and for preventing injury to the operator and other people or damage to property. You must observe these safety precautions. Also, be sure to read and understand the contents of this user's manual.

If this equipment is used in a manner not specified by the manufacturer, the built-in protection provided by the equipment will be impaired.

● Key to symbols

	<p>WARNING Warnings are indicated when mishandling this product might result in death or serious injury to the user.</p>
	<p>CAUTION Cautions are indicated when mishandling this product might result in minor injury to the user, or only physical damage to this product.</p>

WARNING

Before removing, mounting, or wiring the NX-S01, be sure to turn off the module and all connected devices. Failure to do so might cause electric shock.

WARNING

Before starting transmission to the NX-S01, be sure to verify that it is wired properly. A wiring mistake can cause faulty operation or a dangerous accident.

CAUTION

- Use a tool such as a screwdriver to mount and remove the DIN rail locking tab.
- Do not disassemble the NX-S01. Doing so might cause device failure.
- Do not block ventilation holes. Doing so might cause fire or device failure.
- Do not allow wire clippings, metal shavings or water to enter the controller case. They might cause fire or device failure.
- Do not touch live parts such as the power terminals. Doing so might cause electric shock.
- Before wiring the NX-S01, be sure to turn the power OFF. Failure to do so might cause device failure.
- Wire the NX-S01 properly using the specified types of wire and following recognized installation methods. Failure to do so might cause electric shock, fire or device failure.
- Make sure that there are no loose connections. Failure to do so might cause overheating or device failure.
- Ensure the total power consumption of all linked modules does not exceed 70 W. Failure to do so might cause fire or faulty operation.
- Supply power to all linked modules from the same power source. Using two or more power sources can cause fire or faulty operation.
- Do not use unused terminals on the NX-S01 as relay terminals. Doing so might cause electric shock, fire or device failure.
- Do not short-circuit the outputs. Doing so might cause device failure.
- Firmly tighten the terminal screws to the torque listed in the specifications. Insufficient tightening of terminal screws might cause electric shock or fire.
- If there is a risk of a power surge caused by lightning, use a surge absorber (surge protector) to prevent fire or device failure.
- Use the NX-S01 within the operating ranges recommended in the specifications (temperature, humidity, voltage, vibration, shock, mounting direction, atmosphere, etc.). Failure to do so might cause fire or device failure.
- The NX-S01 does not operate for about 60 seconds after turning the power ON. Pay attention to this when using the relay output from the NX-S01 as an interlock signal.
- Be sure to use the designated battery (model No. 83170639-001). Failure to do so could cause fire or rupture.
- When discarding the NX-S01, first remove the battery and then dispose of the module appropriately as industrial waste, following local regulations.
- When discarding the used battery, dispose of it appropriately, following local regulations.
- Before making any change in the factory default settings for the custom application, it is the customer's responsibility to check carefully that there is no problem beforehand.
- The NX-S01 should be handled by a specialist with expertise in electrical circuits.
- If the NX-S01 is used in a manner not specified by the manufacturer, the protection provided by the device may be impaired.
- If the NX-S01 is dirty, wipe it with a soft dry cloth. Never use an organic solvent like benzene or thinner.
- Make sure that devices and equipment connected to the NX-S01 have reinforced insulation suitable for the maximum operating voltage of its power supply, inputs, and outputs.

OVERVIEW

Linked by Ethernet, Network Instrumentation Modules make distributed instrumentation, high-speed communications, and easy installation all possible at the same time. The module also creates value for customers by offering reduced environmental impact, superior product quality, and higher productivity.

The NX-S01 Supervisor Module provides measurement and control functions. It is equipped with a function block programming function, and communicates with the I/O calculation functions of Network Instrumentation Module controller modules, digital/pulse input modules, and digital output modules.

MODEL SELECTION TABLE


Supervisor module

Basic Model No.	Type	Ring connection	Option			Addition
			1	2	3	
NX-S01						Network Instrumentation Module Supervisor module custom application
			N			Non-ring communications
			R			Ring communications
				0		None
				00		None
					0	None
					1	With fault DO
						0 None
						D Inspection certificate
						T Tropicalization treatment
						K Anti-sulfide treatment
						B Tropicalization treatment + Inspection certificate
						L Anti-sulfide treatment + Inspection certificate


NAMES OF PARTS

Body

Indicators on the module vary depending on the model No. (functions).




Base



INSTALLATION

Installation location

Install modules indoors. Minimum clearances are shown in figures.



* The clearance required for battery replacement when the power is on is 60 mm or more.

Install the controller in a location that meets the following criteria:

- No high/low temperature/humidity.
- Free from sulfide gas or corrosive gas.
- Not dusty or sooty.
- Protected from direct sunlight, wind, and rain.
- Little mechanical vibration or shock.
- Not close to high voltage line, welding machine or other electrical noise generating source.
- At least 15 meters away from the high voltage ignition device for a boiler.
- No strong magnetic fields.
- No flammable liquid or gas.
- Indoors
- I/O common mode voltages: voltage to ground is 30 Vrms min., 42.4 V peak min., and 60 V DC min.

Linking modules

The NX-S01 can be linked to other modules using the connectors on the left and right of the base.

When linked, modules share the power supply and RS-485 connection, eliminating the need for wiring. The connection with the module on the right can be disabled using the RS-485 communications cutoff switch on the base.

Mounting procedure

The NX-S01 is used while mounted on a DIN rail.


After mounting the DIN rail and pulling the locking tab completely off, hook the base onto the DIN rail. Then, push the DIN rail locking tab upwards firmly until it clicks into place.

Handling Precautions

- Install the module so that it is vertical, with the DIN rail locking tab at the bottom.
- Link the NX-S01 to other modules before mounting it on a DIN rail.

Attaching the main unit to the base

- (1) Fit the hook on the main unit into the base.
- (2) Push the main unit onto the base until the lever clicks.




! Handling Precautions

- The included base and main unit must be used as a pair.
- Be sure to fit the hook on the main unit into the base first. If this is not done, the hook might be broken during mounting.


■ Removing the main unit from the base

- (1) Grasp the main unit near the front and push it in toward the base.
- (2) While pushing, press the tip of the lever on the top of the main unit.
- (3) While pressing the tip of the lever, rotate the main unit down to remove it.



! Handling Precautions

- Press the tip of the lever. Do not press it down excessively (2 mm or more). Doing so may break the lever.




WIRING

■ Wiring precautions


- Do not run wires outside. The equipment could be damaged in the event of lightning.
- When connecting wires to the power terminals, use crimp terminals with insulating sleeves.
- Check the model number of the controller and the terminal numbers on the label on the side of the module to prevent any wiring errors.
- For connections to power and RS-485 communications terminals, use crimp terminals that are the correct size for M3 screws.
- Be careful not to allow any crimp-type terminal lugs to touch adjacent terminals.
- The signal wires and power wires of the module should be at least 60 cm away from other power wires or power sources. Also, do not pass these wires through the same conduit or wiring duct.
- Before connecting the NX-S01 to other devices in parallel, check their connection conditions carefully.
- To ensure stable operation, the NX-S01 is designed not to operate for 60 seconds after the power is turned ON.
- After wiring, check that there are no mistakes before turning the power ON.

■ Wiring diagrams (model with fault DO)


Connect fault outputs according to the specifications for the 2-piece terminal block.



● Connection diagram




● Fault DO circuit



■ Connecting the power supply

Connect the power terminals as shown below.




The power supply unit must be a UL Class 2 power supply unit.

! Handling Precautions

- Linked modules supply power to each other. Supply power to one of the linked modules.
- I/O wiring to the terminal block or elsewhere should be connected directly to the power supply for I/O, not connected via the base unit.
- If there are multiple wires to the power supply or some other wiring difficulty, add a relay terminal or the like.
- Use a power supply that can supply the total power requirement of the linked modules.

■ Connecting the RS-485 communications

Connect the RS-485 wiring for CPL or Modbus as shown below.



! Handling Precautions

- 0.5 W or greater terminating resistor of $150 \Omega \pm 5\%$ at each end of the communications lines. However, if any device that does not allow a terminating resistor is connected to the same communications line, follow the instructions on that device.
- Be sure to connect the SG terminals to each other. Failure to do so might cause unstable communications.
- For communications wiring, use twisted pair cables.

■ I/O isolation

Items surrounded by solid lines are isolated from other signals.

Power supply (including side connector)*	
Logic circuits Loader jack RS-485, Ethernet communications through side connector* Displays (LED, switch, etc)	Fault DO
Ring communications through side connector*	

* Power, side-connector ring communications, and RS-485/side-connector Ethernet communications are isolated from each other.

BATTERY REPLACEMENT

IMPORTANT

If this module is used as a UL-certified product, the battery should be replaced by a person who not only uses but also maintains equipment that incorporates a UL-certified product.

■ Battery replacement


The backup battery can be replaced whether the power is turned on or off.

! Handling Precautions

- To replace the battery with the power off, make sure that the power was on for 60 minutes or more before turning it off, and complete the replacement within 10 minutes. Failure to do so might cause the backup data to be lost.
- If the battery is replaced when the power is on, the battery indicator may stay lit for about 3 minute after replacement. This is normal, but check that the indicator turns off 3 minute or so after replacement.
- When putting the battery holder back into the unit, push the release lever firmly until it clicks.

● Replacement method with the power off

- (1) Back up the module's data to a PC using the SLP-NX Smart Loader Package.
- (2) After making sure that the power was on for 60 minutes or more, turn the power off.
- (3) Remove the unit from the base, and then remove the battery holder from the bottom of the unit and unplug the connector.
- (4) Remove the battery from the battery holder.
- (5) Set the new battery in the holder, connect the connectors, and hang the battery cable on the hook of the holder.
- (6) Put the battery holder back into the unit and connect the unit to the base.
- (7) Using the SLP-NX, check if the module's date and time are correct. If they are not correct, correct them and then write the backup data that was stored in the PC in step (1) to the unit.



● Replacement method with the power on

- (1) Remove the battery holder from the bottom of the unit, and unplug the connector.
- (2) Remove the battery from the battery holder.
- (3) Set the new battery in the holder, connect the connectors, and hang the battery cable on the hook of the holder.
- (4) Put the battery holder back into the unit.

■ Battery disposal

When discarding the battery, dispose of it appropriately, following local regulations.



DISPOSAL

When discarding the NX-S01, first remove the battery and then dispose of it appropriately as industrial waste, following local regulations.

SPECIFICATIONS

■ Specifications

● Fault digital output contact (optional function: NX-S_____1_)

Outputs:	1
Contact rated voltage:	24 V DC
Allowable voltage:	20.4 to 27.6 V DC
Allowable output current:	100 mA DC max.
Output type:	PhotoMOS relay output (no voltage from A contact)
Polarity:	None
OFF-state leakage current:	100 μ A max.
Maximum ON-state voltage drop:	2 V max. (at 24 V DC, 0.1 A)
Output update cycle:	The same as the cycle time

● Standard conditions

Ambient temperature:	23 \pm 2 $^{\circ}$ C
Ambient humidity:	60 \pm 5 %RH (without condensation)
Rated voltage:	24 V DC
Vibration:	0 m/s ²
Shock:	0 m/s ²
Mounting angle:	Reference plane \pm 3 $^{\circ}$

● Operating conditions

Ambient temperature:	0 to 50 $^{\circ}$ C (below the installed module)
Ambient humidity:	10 to 90 %RH (without condensation)
Allowable operating voltage:	21.6 to 26.4 V DC
Vibration:	0 to 3.2 m/s ² (10 to 150 Hz for 2h each in X, Y, and Z directions)
Shock:	0 to 9.8 m/s ²
Mounting angle:	Reference plane \pm 3 $^{\circ}$
Dust:	0.3 mg/m ³ max.
Corrosive gas:	None
Altitude:	2000 m max.
Pollution degree:	2 (equivalent to normal office environments)

● Transport and storage conditions

Ambient temperature:	-20 to +70 $^{\circ}$ C
Ambient humidity:	5 to 95 %RH (without condensation)
Vibration:	0 to 9.8 m/s ² (10 to 150 Hz for 2h each in X, Y, and Z directions)
Shock:	0 to 300 m/s ² (when installed to the DIN rail, 3 times in the up-down direction)
Package drop test:	Drop height 60 cm (free fall on 1 corner, 3 edges, 6 sides)

● Other specifications

Memory backup type:	Non-volatile (Flash ROM), with SRAM backup battery
Number of flash ROM writing cycles:	100,000 max.
Insulation resistance:	500 V DC, 20 MΩ min. (between power supply terminals 1, 2 and I/O terminals isolated from power supply terminals)
Dielectric strength:	500 V AC, 1 min (between power supply terminals 1, 2 and I/O terminals isolated from power supply terminals)
Power consumption:	4 W max. (under operating conditions)
Power ON operation delay:	Requires approx. 10 s before normal operation begins (under standard conditions)
Inrush current:	12 A max. (under operating conditions)
External dimensions:	30×100×85 mm
Case material/color:	Modified PPO resin, black
Standards compliance:	CE (EN61326-1, For use in industrial locations), cUL (UL61010-1)
Mounting method:	DIN rail
Terminal screw tightening torque:	0.6 ±0.1 N·m
Mass:	200 g max.
Clock IC:	Built-in RTC, ±2.2 s/day, with calendar
Battery life:	3 years (with power off, under standard conditions)
Accessory:	Connector (1) for fault DO
Service parts (sold separately):	Replacement battery model No. 83170639-001

● Communication specifications

● Host communications

Maximum connections:

2, 3 (Only NX-S01 used case)

Note: Total number of sessions of RS-485 and Ethernet communications. Ethernet communications are limited to (Maximum connections – 1) sessions if RS-485 is used.

● Ethernet

Protocol: CPL/TCP, Modbus/TCP

Note: To connect to a host device, be sure to use a communication box. However, if the first four digits of the serial number are 1144 or lower, NX-CB1RR cannot be used.

● RS-485

Protocol: Modbus/RTU, Modbus/ASCII, CPL

Network: Multidrop (up to 31 slave stations for 1 master station)

Signal level: RS-485 compliant

Communications/synchronization type: Half-duplex, start/stop synchronization

Maximum cable length:

500 m

No. of wires: 3

Terminating resistor: External (150 Ω 0.5 W min.)

Transmission speed: Selectable from 4800, 9600, 19200, 38400, 57600, and 115200 bps

Data bits: 7 bits/8 bits

Stop bits: 1 bit/2 bits

Parity bit: Even parity, odd parity, or non-parity

● Loader

Dedicated loader: SLP-NX-J70, SLP-NX-J70PRO, SLP-NX-J71, SLP-NX-J71PRO

● Communication box (sold separately, model No. NX-CB_ _ _ _ _)

Ports: 4

Communication path type:

- Ethernet port 1 and 2
IEEE 802.3/IEEE 802.3u 10BASE-T/100BASE-TX (with Auto Negotiation and Auto MDI/MDI-X functions)
- Ethernet ports 3 and 4 (option 0), Ethernet port 3 (option 1)
IEEE802.3u 100BASE-TX (with full duplex and Auto MDI/MDI-X functions. The auto-negotiation function on a connected device should be enabled except when the device is connected between communication boxes.)
- Ethernet port 4 (option 1)
IEEE802.3u 100BASE-FX (full duplex, wavelength 1300 nm)

Connector:

- 100BASE-TX connector: RJ-45
- 100BASE-FX connector: 2-core LC

Cable:

- 100BASE-TX cable
UTP cable (4P), Cat 5e min. (straight) (both ends, ANSI/TIA/EIA-568-B), 100 m max.
- 100BASE-FX cable
Multi-mode graded index optical fiber, GI-50/125 or GI-62.5/125 (2-cores), 2 km max.

Note: For handling of optical fiber, see the manufacturer's instructions.

● Communication adaptor (sold separately, model Nos. NX-CL1_ _ _ _ _ , NX-CR1_ _ _ _ _)

Ports: 1

Communication path type:

IEEE 802.3u 100BASE-TX (with full duplex and Auto MDI/MDI-X functions. The auto-negotiation function on a connected device should be enabled.)

Connector: RJ-45

Cable: UTP cable (4P) Cat 5e min. (straight) (both ends ANSI/TIA/EIA-568-B)

● Terminal adaptor (sold separately, model Nos. NX-TL1_ _ _ _ _ , NX-TR1_ _ _ _ _)

An adaptor used as a chain connection ring communications terminal (Ethernet path in the base)

● Replacement battery (sold separately, model No. 83170639-001)

Configuration: Button battery with connection cable

Quantity: 1 item

● Connector cap (sold separately, model Nos. 80700224-010 (male) or 80700225-010 (female))

Used to protect the male and female side connectors.


The right connector is male and the left is female when viewed from the front of the module.

Quantity: 10

External dimensions


Model without options

Unit: mm



Model with fault DO

Unit: mm



This product is conducted the type approval tests in accordance with Guideline for Type Approval Test of Electric and Electronic Products 2006 with CCS witness and passed.

基于SJ/T11364-2014「电子电气产品有害物质限制使用标识要求」的表示式样

产品中有害物质的名称及含量

零部件名称	有毒害物质或元素					
	铅 (Pb)	汞 (Hg)	镉 (Cd)	六价铬 (Cr ⁶⁺)	多溴联苯 (PBB)	多溴二苯醚 (PBDE)
本体	×	○	○	○	○	○
底板	×	○	○	○	○	○


本表格依据SJ/T 11364 的规定编制。

○: 表示该有害物质在该部件所有均质材料中的含量均在 GB/T 26572规定的限量要求以下。

×: 表示该有害物质至少在该部件的某一均质材料中的含量超出GB/T 26572规定的限量要求。



CP-UM-5689JE-1



R.O.C. Invention Patent No. I402752.

Azbil Corporation
Advanced Automation Company

1-12-2 Kawana, Fujisawa
Kanagawa 251-8522 Japan

URL: <http://www.azbil.com>

Specifications are subject to change without notice. (09)

azbil

1st edition: Apr. 2012 (V)
5th edition: Nov. 2017 (F)