



# Certificate of Compliance

**Certificate:** 70018783

**Master Contract:** 262375

**Project:** 70018783

**Date Issued:** December 17, 2014

**Issued to:** TRIAC  
dba A-T Controls Inc.  
9955 International Blvd  
Cincinnati, OH 45246  
USA  
**Attention:** Ron Ruehlmann

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Heather Sell  
Heather Sell

## PRODUCTS

**CLASS 3221 02** - VALVES - General purpose Actuators

**CLASS 3221 82** - VALVES - Actuators - Certified to US Standards

APL Series Limit Switch Boxes – position signaling and indicating for valves or actuators.

APL2xxN series, Type 4X

xx =	Electrical
10, 13	250Vac max, 5.6A max
20	8.2Vdc, 0-100mA
23	5-60Vdc, 4-100mA

APL3xxN series, Type 4X

xx =	Electrical
10 - 16	250Vac max, 5.6A max
20	8.2Vdc, 0-100mA
23	5-60Vdc, 4-100mA
30	200Vdc max, 1.5A max



**Certificate:** 70018783

**Project:** 70018783

**Master Contract:** 249581

**Date Issued:** December 17, 2014

---

Notes:

- 1) Not intended for direct connection with motor(s).

**APPLICABLE REQUIREMENTS**

C22.2 No 139-13 – Electrically Operated Valves

ANSI/UL 429 (7th Ed) – Electrically Operated Valves

C22.2 No 94.1-07/UL 50 (12th Ed) - Enclosures for Electrical Equipment, Nonenvironmental Considerations

C22.2 No 94.2-07/UL 50E (1st Ed) - Enclosures for Electrical Equipment, Environmental Considerations



## *Supplement to Certificate of Compliance*

**Certificate:**

**Master Contract:**

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70018783	Dec 17 2014	New certificate for TRIAC division of A-T Controls, Inc with models for ordinary location. Report reference 249581-2673306.