



11

EC - DECLARATION OF CONFORMITY

We,

Dwyer Instruments, Inc.
 P.O. Box 373
 Michigan City, IN 46361, USA
 (219) 879-8868

declare under our sole responsibility that our Series RSM Room Status Monitor to which this declaration relates are in conformity with the following EC Directives and harmonized standards:

Directive 2004/108/EC (EMC)

CISPR11 (2006) Industrial, Scientific and Medical (ISM) Radio-Frequency Equipment-Electromagnetic Disturbance Characteristics-Limits and Methods of Measurement

EN 55011 (2007) Industrial, Scientific and Medical (ISM) Radio-Frequency Equipment – Electromagnetic Disturbance Characteristics – Limits and Methods of Measurement

IEC 61000-3-2 (2006) Electromagnetic Compatibility (EMC) - Part 3-2: Limits-Limits for Harmonic Current Emissions (Equipment Input Current \leq 16A per Phase)

IEC 61000-3-3 (2005) Electromagnetic Compatibility (EMC) - Part 3-3: Limits-Limitation of Voltage Changes, Voltage Fluctuations and Flicker in Public Low-Voltage supply Systems-Equipment with Rated Current \leq 16A per Phase and not Subject to Conditional Connections

IEC 61000-4-2 (2001) Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

IEC 61000-4-3 (2006) Electromagnetic Compatibility (EMC) - Part 4-3 Testing and Measurement Techniques -Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

IEC 61000-4-4 (2004) Electromagnetic Compatibility (EMC) - Part 4-4 Testing and Measurement Techniques –Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-5 (2006) Part 4-5 Testing and Measurement Techniques – Surge Immunity Test

IEC 61000-4-6 (2007) Electromagnetic Compatibility (EMC) - Part 4-6 Testing and Measurement Techniques -Immunity to Conducted Disturbances, Induced by Radio-Frequency Fields

IEC 61000-4-11 (2004) Electromagnetic Compatibility (EMC) - Part 4-11 Testing and Measurement Techniques – Voltage Dips, Short Interruptions and Voltage Variations Immunity Tests

EN 55011 (2007) Industrial, Scientific and Medical (ISM) Radio-Frequency Equipment – Electromagnetic Disturbance Characteristics – Limits and Methods of Measurement

EN 61326-1 (2006) Electrical Equipment for Measurement, Control, and Laboratory Use - EMC Requirements -Part 1: General Requirements

EN 61326-2-3 (2006) Electrical Equipment for Measurement, Control and Laboratory Use -EMC Requirements – Part 2-3: Particular Requirements - Test Configuration, Operational Conditions and Performance Criteria for Transducers with Integrated or Remote Signal Conditioning

Directive 2006/95/EC (Low Voltage Directive)(Codes B & D Only)

IEC 61010-1:2001 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use Part 1

The authorized representative located within the Community is:

Dwyer Instruments Ltd
Unit 16, The Wye Estate, London Road
High Wycombe, Bucks HP11 1LH-U.K.
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, Inc.

A handwritten signature in black ink, appearing to read "John G. ...", is written over a horizontal line.

Senior Regulatory Engineer

Michigan City, Indiana, USA
3/18/11