



#### Introduction

This guide provides CMA actuator range motor data at 25 °C ambient temperature for the following power supply voltages:

	1-Phase 50 Hz / 60 Hz	110 VAC
		115 VAC
		120 VAC
		208 VAC
		220 VAC
		230 VAC
		240 VAC
	DC	24 VDC Only

Note: Supply voltage tolerance +/- 10%. Supply frequency tolerance +/- 5%

For AC supplies, the CMA uses a linear power supply to convert to 24 VDC. This voltage is used to feed the main control electronics and DC brushless motor.

#### Design criteria

The CMA utilises a special brushless DC motor, developed for high efficiency, continuous S9 / Class D rated unrestricted modulation. Using a brushless DC motor enables the actuator to perform the high modulation duty for millions of operations with minimal wear.

# CMA motor design

CMA motors are of a low inertia, brushless 24 VDC permanent magnet type and are class F insulated.

#### **CMA** motor control protection

The primary protection for the motor is the current sensor capabilities which monitors the amount of current being supplied to the motor. Using this method and comparing the value to the load limits set in the configuration, effective motor and more importantly valve protection is achieved. Thermostats in the motor also protect the motor from overheating, although the likelihood of this happening is remote due to the high modulation design.

The use of load and temperature protection along with the sophisticated motor position control eliminates the need for traditional protection methods normally used for industrial motors

#### Power supply cable sizing

As a minimum requirement, cables must be sized to ensure the volt drop does not exceed 10% of nominal supply voltage at rated load.

#### **Fuse selection**

Due to the unique nature of the motor duty and taking into account the comprehensive control protection of the CMA, sizing of fuses should be based upon protecting the power cable to the actuator.

#### Frequency converter and UPS

Where UPS systems are required, the power supply should have negligible harmonic distortion. In general terms actuators are designed to operate on power supplies conforming to recognised power supply standard such as EN 50160 – Voltage Characteristics of Electricity Supplied by Public Distribution Systems.



### **Keeping the World Flowing**

# **CMA** Range

## **Electric Motor Performance Data**

#### Estimated electric motor performance data for CMA range

Actuator		120 VAC		240 VAC		24 VDC		
		Power (W)	Current (A)	Power (W)	Current (A)	Power (W)	Current (A)	
Linear								
CML-100/250	Stationary	2.37	0.06	2.19	0.03	0.72	0.03	
CIVIL-100/230	Moving full load	44.50	0.49	44.50	0.25	37.83	1.58	
CML-750	Stationary	2.37	0.06	2.19	0.03	0.72	0.03	
CIVIL-750	Moving full load	59.50	0.71	59.50	0.35	50.58	2.11	
CML-1500	Stationary	6.30	0.13	7.26	0.22	0.58	0.02	
CIVIL-1500	Moving full load	73.08	0.67	74.09	0.43	73.44	3.06	
CM 2000	Stationary	6.31	0.13	7.34	0.22	0.58	0.02	
CML-3000	Moving full load	137.03	1.20	136.36	0.67	133.48	5.56	
Part-turn Part-turn								
CMQ-250/500	Stationary	2.37	0.06	2.19	0.03	0.72	0.03	
CIVIQ-250/500	Moving full load	38.50	0.43	38.50	0.21	32.73	1.36	
CMQ-1000	Stationary	2.37	0.06	2.19	0.03	0.72	0.03	
CIVIQ-1000	Moving full load	30.81	0.37	30.81	0.18	26.19	1.09	
Rotary								
CMR-50	Stationary	2.37	0.06	2.19	0.03	0.72	0.03	
CIVIN-50	Moving full load	18.75	0.21	18.75	0.10	15.94	0.66	
CMR-89/100/200	Stationary	2.37	0.06	2.19	0.03	0.72	0.03	
CIVIK-89/100/200	Moving full load	37.50	0.42	37.50	0.21	31.88	1.33	
CMR-125/250	Stationary	2.37	0.06	2.19	0.03	0.72	0.03	
CIVIN-123/23U	Moving full load	59.50	0.71	59.50	0.35	50.58	2.11	

Note: These figures do not include optional items. For example, communication boards (Profibus®, HART®, Modbus®, Pakscan<sup>TM</sup>), Input output board (RIRO) or Reserve Power Pack (RPP). The power and Amp levels reflect actuator rated or "modulating running" loads not "shut off" loads.

A full listing of the Rotork sales and service network is available on our website.

www.rotork.com

Corporate Headquarters
Rotork plc
tel +44 (0)1225 733200
fax +44 (0)1225 333467
email mail@rotork.com

Rotork Controls Inc. tel +1 (585) 247 2304 fax +1 (585) 247 2308

# rotork

PUB094-006-00 Issue 11/18

As part of a process of on-going product development, Rotork reserves the right to amend and change specifications without prior notice. Published data may be subject to change. For the very latest version release, visit our website at www.rotork.com

The name Rotork is a registered trademark. Rotork recognises all registered trademarks Published and produced in the UK by Rotork. POWTC1118

Rotork is a corporate member of the Institute of Asset Management

